

SOLICITATION NO. W911WN-05-B-0003

EMSWORTH LOCKS AND DAM
BACK CHANNEL REHABILITATION
OHIO RIVER, PENNSYLVANIA

A

M

E

N

D

M

E

N

T

NUMBER 3

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">0003</div>		3. EFFECTIVE DATE <div style="text-align: center;">25-AUG-2005</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">W81ET4-5159-5022</div>		5. PROJECT NO. (If applicable)	
6. ISSUED BY US ARMY ENGR DISTRICT PGH WM S MOORHEAD FEDERAL BLDG 21ST FLOOR 1000 LIBERTY AVENUE PITTSBURGH PA 15222-4186 ARLENE M. BIGGER (412)395-7478		CODE <div style="text-align: center;">W911WN</div>		7. ADMINISTERED BY (If other than Item 6) US ARMY ENGR DISTRICT PGH 727 WM S MOORHEAD FEDERAL BLDG 1000 LIBERTY AVENUE PITTSBURGH PA 15222-4186		CODE <div style="text-align: center;">W911WN</div>	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP code)				(X)		9A. AMENDMENT OF SOLICITATION NO. <div style="text-align: center;">W911WN-05-B-0003</div>	
				X		9B. DATED (SEE ITEM 11) <div style="text-align: center;">29-JUL-2005</div>	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
(X)		A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
		B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO AUTHORITY OF FAR 43.103(b).					
		C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
		D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
SEE ATTACHED							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)				BY _____ (Signature of Contracting Officer)			

The following changes are made to the solicitation for Gate, Machinery and Electrical Replacement, Emsworth Dam – Back Channel, Ohio River, Allegheny County, Pennsylvania.

Section 01100 – GENERAL REQUIREMENTS

Paragraph 1.5.3.1. Delete the third (3rd) subparagraph and substitute the following revised subparagraphs:

“Any proposed temporary mooring facilities developed below Ordinary High Water (OHW) (El 710.0) shall comply with the conditions of the Corps of Engineers Nationwide Permit (NWP) No. 33, "Temporary Construction, Access & Dewatering," which is found in Public Notice No. 02-NWP3, dated September 4, 2002 (<http://www.lrp.usace.army.mil/or/or-f/panwd.pdf>). Typical temporary sheetpile bulkheads, sheetpile cells, and mooring guides placed below OHW are within the scope of NWP No. 33. The Contractor is responsible to design temporary structures that comply with the conditions of the NWP.

If fill below OHW is proposed, the Contractor must comply with the terms of a PaDEP GP-8 (<http://www.dep.state.pa.us/dep/efacts/GeneralPermitsListing.htm>). The GP-8 application will be submitted to the Resident Engineer, which will in turn be submitted to the Regulatory Branch and forwarded to the PaDEP for registration.

If excavation above OHW is proposed, the Contractor will prepare and maintain on-site an erosion and sediment control plan in compliance with applicable state and local requirements. In accordance with Section 00700 CONTRACT CLAUSES, paragraph "PERMITS AND RESPONSIBILITIES," the Contractor shall be responsible to secure all necessary permits required by Federal, state and local laws for any development above OHW.”

Paragraph 1.7.5. Delete the fifth (5th) subparagraph and substitute the following revised subparagraph:

“Any proposed temporary mooring facilities developed below Ordinary High Water (OHW) (El 710.0) shall comply with the conditions of the Corps of Engineers Nationwide Permit (NWP) No. 33, "Temporary Construction, Access & Dewatering," which is found in Public Notice No. 02-NWP3, dated September 4, 2002 (<http://www.lrp.usace.army.mil/or/or-f/panwd.pdf>). Typical temporary mooring cells, dolphins, or H-piles placed below OHW are within the scope of NWP No. 33. The Contractor is responsible to design temporary mooring facilities that comply with the conditions of the NWP.

Amendment 0001

Page 11 – Questions and Answers – The solicitation number in the answer to the following question is corrected. Solicitation W911WN-05-B-0003, Section 09940, was corrected by amendment 0002 to require gates to be completely shop painted.

Q. Section 09940 of Solicitation W911WN-05-B-0003 at Section 09940 schedules the fourth coat of paint at the gates and the second and third coats of paint at the appurtenant items to be field applied.

A. Specification for Solicitation W911WN-05-B-0003 has been revised by amendment to require gates to be completely shop painted with field touch up.